

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 79/26

Dated: 24/08/2026

It is certified that an inspection team headed by Mr Eknath Pardhi from Primary Health Centre, Maan Taluka- Mulshi Pune-411057 (PHED) inspected MIS School, Maan, Taluka-Mulshi, Pune-411057 on 24/08/2026 and on the basis of Water Test Report (Attached) bearing No : SPHLPUNE/Desk-80/Bact Section/Water analysis report 2026-1391 dt 03/08/2026 & SPHLPUNE/DESK-79/756/2026 Dt 20/08/2026 of State Public Health Laboratory, Pune (Lab) certified that the MIS School, Maan has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23.08.2027


Medical Officer
Primary Health Center Maan,
Tal. Mulshi, Dist. Pune

Name : Dr Mayadevi Gujar

Designation : Medical Officer Incharge

Name & Address of the Office / Department : Primary Health Centre:

Maan Taluka- Mulshi, Pune-411057

To

Principal,

MIS School, Maan, Tal-Mulshi, Pune-411057

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

					
STATE PUBLIC HEALTH LABORATORY, PUNE					
Dy Director tele No. 26330509 (P) Office Tele No. 26330225 (O)		Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in			
HEALTH SERVICES:		No.SPHPUNE/Desk-80/Bact.Section/water analysis report/ 03/8/ / 2026 Date : 2026 1391			

Bacteriological Report of water Sample

Sender's Name	MIS School Maan, Tal – Mulshi, Dist - Pune. 411057.
Sender's letter No. & date	---/ 30-07-2026
Lab. Reference No.	1106 / 4460
Date of sample collection	30-07-2026
Date of sample received	30-07-2026
Analysis start date	30-07-2026

	Sample Description	Bacteriological Analysis result			
		Most Probable Number of bacteria found per 100 ml of Water Sample			
		Coliforms	Thermotolerant Coliforms	E.coli	Conclusion
1.	MIS School Maan, Tal – Mulshi, Dist - Pune – Filter (Outlet)	0	-	-	Potable

Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. 340/-

Receipt No. : 9944037

Date : 30-07-2026


Chief Bacteriologist
State Public Health Laboratory, Pune



DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
 Near St. Mary School And Church, Pune 411001

Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com



HEALTH SERVICES

NO.:-SPHLPUNE/Desk -79/ 756/ 2026.DATE :- 20 /08/2026.

Report on Chemical Analysis of Water

Sent by :- MIS School, Maan , Tal. Mulshi Dist. Pune.

With Ref. letter No :- /2026-27

Dated :- 30/07/2026

Date of Receipt :- 30/07/2026

Date of Examination :- 31/07/2026



TC-11706

(All the Analytical Results are in mg. / Lit. except pH , Turbidity .

PARAMETERS UNDER SCOPE

SR · N O	TEST PARAMETER	S.No. - 1 (P-500) Filter Outlet Water	Test Method	BIS Specifications 10500 : 2012	
				Desirable limit	Permissible limit
1	pH Value	7.43	FSSAI, Manual of methods Of Analysis of Water With 2016.	6.5 to 8.5	No relaxation
2	Chlorides (as Cl)	15.59	FSSAI, Manual of methods Of Analysis of Water With 2016.	250	1000
3	Total Hardness (as Caco3)	13.53	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600
4	Alkalinity (as Caco3)	27.97	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600

P.T.O